


PD-PIR158 Infrared Sensor Instruction



Summary


This product is an energy automatic sensor switch, it can identify day and night. It adopts infrared detector, IC and SMD technology, when someone enters its detecting range and triggers it to work, the infrared detector turns on the lamp, after he leaves its range, the lamp will turn off automatically. It can detect the ambient light illumination automatically and set and adjust the value according to the fact need. Such as, the light will turn on and work when the ambient light illumination is under setting value. Once it exceeds the setting value, the light will stop working. It can be installed in indoor, corridor and public-building.

Specifications



Power source: 220-240VAC, 50Hz
 Rated load: 800W Max.
 Time setting: 10s, 2 Min, 6 Min, 12 Min (adjustable)
 Light-control: 10LUX, 50LUX, 150LUX, >300LUX (adjustable)

Detection range: 8±1m (24°C) (adjustable)
 Detection angle: 100°
 Working temperature: -10~+40°C
 Working humidity: ≤93%RH

Sensor information




8±1m (24°C)
Correct moving orientation




100°
Detection angle

Name of each part




The nuts design at the head of the sensor makes it more convenient to fix on the installation object. There is also wiring for fixing made of plastic at its bottom in order to add its strength when being installed.



Function

- Adopts 6-bit DIP switch:
 - You can select working light to work only in the light below 10lux or in any light;
 - Adjustable sensitivity;
 - Choose working time-delay of the load: 10s, 2Min, 6Min, 12Min;
- The time that the load work can delay automatically: it re-computes time after the last sensing;
- Out connect infrared detector and sensitization resistor;
- Simple structure and using convenient.



1	1
0	0

 S1 S2

S1	S2	Detection range
0	0	25%
0	1	50%
1	0	75%
1	1	100%

1	1
0	0

 S3 S4

S3	S4	Time setting
0	0	10s
0	1	2min
1	0	6min
1	1	12min

1	1
0	0


 S5 S6

S5	S6	Light-control
0	0	10 LUX
0	1	50 LUX
1	0	150 LUX
1	1	>300 LUX


NOTE:The maximum detection distance: $8 \pm 1m$

ATTENTION: When use this product, please adjust the sensitivity to an appropriate position you need, please do not adjust the sensitivity to maximum, to avoid the product does not work normally caused by wrong motion. Because the sensitivity is too high easily detect the wrong motion by wind blowing leaves & curtains, small animals, and the wrong motion by interference of power grid & electrical equipment. All those lead the product does not work normally !
When the product does not work normally, please try to lower the sensitivity appropriately, and then test it.



Operating principle of time setting



Pay attention to installation



Operating principle of the light-control




For occasions

It can be installed in indoor, corridor and public-building.

Installed inside on the device with non-metallic materials.

Eg, add the sensor, from one normal lighting to automatic sensor lamp.



Attention

- The installing personnel should be electrician or with correlation experience;
- Be sure not to install the unit in the place where sun shine, current and temperature change obviously, for example air conditioning, air warm;
- Do not choose the sway object as installing base;
- In front of sense range there should be no obstruction or moving object to influent its detecting.

Remark

1. Keep the sensor face to the area where human usually move.
2. Keep the sensor face to the position of the ambient light in order to get much more exact illuminance setting.
3. If detect the signal again within the time setting, the time setting will be over lied.

Some problem and solved way

1、 The load do not work:

- a: Please check if the connection-wiring of power and load is correct;
- b: Please check if the load is good ;
- c: Please check if the working light set correspond to light-control.

2、 The sensitivity is poor:

- a: Please check if there has hinder in front of the detection window to effect to receive the signal;
- b: Please check if the ambient temperature is too high;
- c: Please check if the induction signal source is in the detection fields;
- d: Please check if the installation height corresponds to the height showed in the instruction;
- e: Please check if the moving orientation is correct.

3、 The sensor can not shut off the load automatically:

- a: Please check if there is continual signal in the detection field;
- b: Please check if the time setting is the longest;
- c: Please check if the power correspond to the instruction;
- d: Please check if the temperature near the sensor change obviously, such as air condition or central heating etc.