



Product Service

Attestation of Conformity

No. N8A 119896 0003 Rev. 00

Holder of Attestation: **Zhejiang Liya New Energy Co.,Ltd**
No385,Jing 8 Road, Yueqing Economic Development Zone
325600 Yueqing City, Zhejiang Province
PEOPLE'S REPUBLIC OF CHINA

Product: **AC electric vehicle charging station
(electric vehicle charger)**

This Attestation of Conformity is issued on a voluntary basis according to the Low Voltage Directive 2014/35/EU relating to electrical equipment designed for use within certain voltage limits. It confirms that the listed equipment complies with the principal protection requirements of the directive and is based on the technical specifications applicable at the time of issuance. It refers only to the particular sample submitted for conformity assessment. For details see: www.tuvsud.com/ps-cert

Test report no.: 705202301601-00

Date, 2023-10-13

(Pengdong Yang)

Page 1 of 2

This Attestation does not replace the regulatory EU Declaration of Conformity (DoC) and does not allow for CE marking. After preparation of the necessary documentation and establishing compliance to requirements of all applicable directives, the manufacturer may sign a DoC and apply the CE marking. The DoC is issued under the sole responsibility of the manufacturer.





Product Service

Attestation of Conformity

No. N8A 119896 0003 Rev. 00

Model(s): EVB-116-TC2, EVB-316-TC2, EVB-132-TC2,
EVB-332-TC2, EVB-116-FC, EVB-316-FC,
EVB-132-FC, EVB-332-FC

Parameters:

Rated voltage (V):	3/N/PE ~230/400V	EVB-316-TC2, EVB-332-TC2, EVB-316-FC, EVB-332-FC
	1/N/PE ~230V	EVB-116-TC2, EVB-132-TC2, EVB-116-FC, EVB-132-FC
Rated current (A):	16	EVB-316-TC2, EVB-316-FC, EVB-116-TC2, EVB-116-FC
	32	EVB-332-TC2, EVB-332-FC, EVB-132-TC2, EVB-132-FC
Rated power (kW):	3.5	EVB-116-TC2, EVB-116-FC
	7	EVB-132-TC2, EVB-132-FC
	11	EVB-316-TC2, EVB-316-FC
	22	EVB-332-TC2, EVB-332-FC
Connection method:	Case C	EVB-316-TC2, EVB-332-TC2, EVB-116-TC2, EVB-132-TC2
	Case B	EVB-316-FC, EVB-332-FC, EVB-116-FC, EVB-132-FC
Rated frequency (Hz):	50/60	
Degree of protection:	IP 55	
Protection class:	I	
Operating temperature:	-40°C to 45°C	

Tested EN IEC 61851-1:2019

according to:

Page 2 of 2

This Attestation does not replace the regulatory EU Declaration of Conformity (DoC) and does not allow for CE marking. After preparation of the necessary documentation and establishing compliance to requirements of all applicable directives, the manufacturer may sign a DoC and apply the CE marking. The DoC is issued under the sole responsibility of the manufacturer.

